

Ref: 17010105
 Dated. 01-08-2017

EVALUATION REPORT

1. Name of Procuring Agency : PIAC.
2. Method of Procurement /Services: Single Stage two Envelope.
3. Title of Procurement : Procurement of Flame Detector
4. Tender Inquiry No : 17010105
5. PPRA Ref # No : TS321401E
6. Technical Proposals Opened On : 31-07-2017 11.00hrs.
7. No of Bid Evaluation : (04).
8. Details of Bid Evaluation : Fire & Safety Department
9. Financial Opened : 02-08-2017

Result of the evaluation report is as under:

Specifications	Accepted OR Rejected (Please specify the reason , if Rejected)
1 / 4 Flame Detector Model : AH-0014 Brand : Horing lih Taiwan	ACCEPTED
2 / 4 Flame Detector Model : AH-0014 Brand : Horing lih Taiwan	ACCEPTED
3 / 4 Flame Detector Model : FEUV2000 Brand : ZETA - UK	---- REJECTED --- Not meeting the PIA requirement as Physically checked with our existing system installed at Main ISPHANI HANGER . 3 / 4 quoted ZETA Brand which is not compatible / operatable , Only Horing Lih Taiwan was compatible to our existing system
4 / 4 Smoke Detector Model : AH-0311 Brand : Horing lih Taiwan	---- REJECTED --- Not meeting the PIA requirement as 4 / 4 vender quoted the Smoke Detector instead of Flame Detector which is totally different Item hence Rejected

Manager Purchase Commercial
Purchase Commercial Department

Note:
 To be uploaded on PIA & PPRA Website